

We only received one question so here it is with response;

Q: The engineer from GenTech just reached out to me to see what size fuel tank that is needed for the generator there is not a size for it on the plans.
Can you please clarify?

A: The fuel capacity shall provide a minimum of 8 hours of run time.

Thank you,

MICHAEL "MAC" MCMILLAN, CBO
Building Official · Project Manager

BROWN & ASSOCIATES
15601 N. 40th Street, Building #130
Phoenix, AZ 85032

Cell 602-319-9666
Office 480-991-3751
Fax 480-596-5065

Mac@brownandassociates.net
www.brownandassociates.net
